

CERTIFICATE OF ANALYSIS

Batch No:	18-29838	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	697782	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	Country Fire Authority	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	PO Box 717 PATTERSON LAKES VIC 3197	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Client Manager 02-Jul-2018
<i>PO No:</i>	Not Available	<i>Date Sampled:</i>	
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	02-Jul-2018
<i>ALS Program Ref:</i>	CFA	<i>Date Issued:</i>	09-Jul-2018
<i>Program Description:</i>	Miscellaneous Analyses		
<i>Client Ref:</i>	WQMP - Bangholme		

The sample(s) referred to in this report were analysed by the following method(s) under NATA Accreditation No. 992. The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Alg. ScCnt	MB006	Scoresby	BOD5	WP030	Scoresby
Colilert (2000)	MM514	Scoresby	pH	WA005	Scoresby
Ps aeruginosa	MM528	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Result for pH in water tested in the laboratory may be indicative only as holding time is generally not achievable.

Signatories

These results have been electronically signed by the authorised signatories indicated below. Electronic signing has been carried out in compliance with procedures specified in 21 CFR Part 11

Name	Title	Name	Title
	Team Leader Nutrients		Analyst
	Team Leader Biology		Analyst

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.
 MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.
 Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link





Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5709419	CFAB02	South Megalitre Tank	WATER	02/07/18 11:50
5709420	CFAB03	North Megalitre Tank	WATER	02/07/18 11:30

Analysis - Analyte	Sample No. Site Code Units	5709419	5709420
		CFAB02	CFAB03
pH - pH, units	Units	7.8	7.8
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	3	5
Alg. ScCnt - Algal analyses		NR IND	NR IND
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

IND Reported independently on separate report

A blank space indicates no test performed.