

## CERTIFICATE OF ANALYSIS

**Batch No:** 18-33118  
*Final Report* 706845

**Client:** Country Fire Authority

**Contact:**

**Address:** PO Box 717  
 PATTERSON LAKES VIC 3197

*Page* **Page 1 of 2**

*Laboratory* Scoresby Laboratory  
*Address* Caribbean Business Park,  
 22 Dalmore Drive,  
 Scoresby,  
 VIC 3179

*Phone* 03 8756 8000  
*Fax* 03 9763 1862

*Contact:* Client Manager

**PO No:** 4500376037 V703

**Sampler Name:**

**ALS Program Ref:** CFA

**Program Description:** Miscellaneous Analyses

**Client Ref:** WQMP - Bangholme

**Date Sampled:** 28-Aug-2018

**Date Samples Received:** 28-Aug-2018

**Date Issued:** 03-Sep-2018

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Colilert (2000)	MM514	Scoresby	Ps aeruginosa	MM528	Scoresby

**Signatories**

Name	Title	Name	Title
	<b>Team Leader Microbiology</b>		<b>Analyst</b>



Accreditation No. 992  
 Accredited for compliance with  
 ISO/IEC 17025 - Testing



Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5737195	CFAB02	South MegalitreTank- Tap on tank	WATER	28/08/18 11:00
5737196	CFAB03	North MegalitreTank- Tap on tank	WATER	28/08/18 10:40

Analysis - Analyte	Sample No. Site Code Units	5737195	5737196
		CFAB02	CFAB03
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

*A blank space indicates no test performed.*