

CERTIFICATE OF ANALYSIS

Batch No:	18-43600	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	714264	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	Country Fire Authority	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>	PO Box 717 PATTERSON LAKES VIC 3197	<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Client Manager
 <i>PO No:</i>	 4500376037 V703	<i>Date Sampled:</i>	08-Oct-2018
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	08-Oct-2018
<i>ALS Program Ref:</i>	CFA	<i>Date Issued:</i>	12-Oct-2018
<i>Program Description:</i>	Miscellaneous Analyses		
<i>Client Ref:</i>	WQMP - Bangholme		

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Alg. ScCnt	MB006	Scoresby	Colilert (2000)	MM514	Scoresby
Ps aeruginosa	MM528	Scoresby			

Signatories

Name	Title	Name	Title
	Team Leader Biology		Team Leader Microbiology
	Analyst		

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link





Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5823209	CFAB02	South Megalitre Tank- Tap on tank	WATER	08/10/18 09:10
5823210	CFAB03	North Megalitre Tank- Tap on tank	WATER	08/10/18 09:20

Analysis - Analyte	Sample No. Site Code Units	5823209 CFAB02	5823210 CFAB03
	Alg. ScCnt - Algal analyses		NR IND
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

IND Reported independently on separate report

A blank space indicates no test performed.