

CERTIFICATE OF ANALYSIS

Batch No:	19-07127	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	741511	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	Country Fire Authority	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>		<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	Client Manager

<i>PO No:</i>	4500376181 v704	<i>Date Sampled:</i>	22-Feb-2019
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	22-Feb-2019
<i>ALS Program Ref:</i>	CFASUN	<i>Date Issued:</i>	28-Feb-2019
<i>Program Description:</i>	Miscellaneous Analyses for CFA Sunraysia Campus		
<i>Client Ref:</i>	Sunraysia - WQMP		
	<u>The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.</u>		

Analysis	Method	Laboratory	Analysis	Method	Laboratory
DO (Field)	EN67.2	Scoresby	EC (Field)	EN67.2	Scoresby
pH (Field)	EN67.2	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	Colilert (2000)	MM514	Scoresby
Enterolert	MM517	Scoresby	Ps aeruginosa	MM528	Scoresby
SS at 104+/- 2°C	WA025	Scoresby			

The monochloramines component of Field Chlorine is not NATA accredited

Signatories

Name	Title	Name	Title
	Client Manager		Analyst
	Analyst		Chemist
	Analyst		



Samples collected by ALS according to procedure EN/67.
 Soil microbiological testing was commenced within 4 days from the day collected unless otherwise stated.
 MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.
 MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.
 Calculated results are based on raw data.
 Legionella species refers to Legionella species other than Legionella pneumophila
 Measurement Uncertainties values for your compliance results are available at this link



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5982812	SU_HY01	Hydrant	WATER	22/02/19 06:55

Analysis - Analyte	Sample No. Site Code Units	5982812 SU_HY01
Temp (Field) - Temperature (Field)	°C	22.8
pH (Field) - pH (Field)	Units	6.8
EC (Field) - Electrical Conductivity (Field)	uS/cm	200
DO (Field) - Dissolved Oxygen (Field)	mg/L	7.9
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0
Enterolert - Enterococci MPN Enterolert	orgs/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0

A blank space indicates no test performed.