



CERTIFICATE OF ANALYSIS

Batch No: 19-41008

Final Report 777821

Client: Contact:

Address:

PO No:

Country Fire Authority

Page

Page 1 of 2

Laboratory

Address

Scoresby Laboratory Caribbean Business Park.

22 Dalmore Drive,

Scoresby, VIC 3179

03 8756 8000 Phone 03 9763 1862 Fax

Contact:

Date Sampled:

17-Sep-2019

Date Samples Received:

17-Sep-2019

Date Issued:

23-Sep-2019

ALS Program Ref:

Program Description: Client Ref:

Sampler Name:

CFALONG Miscellaneous Analysis for CFA Longerenong

4500376081 v707

WQMP - Longerenong

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service .

Analysis	Method	Laboratory	Analysis	Method	Laboratory
DO (Field)	EN67.2	Scoresby	EC (Field)	EN67.2	Scoresby
pH (Field)	EN67.2	Scoresby	Redox (Field) #	EA075FD	Scoresby
Temp (Field)	EN67.2	Scoresby	BOD5	WP030	Scoresby
Colilert (2000)	MM514	Scoresby	Enterolert	MM517	Scoresby
Ps aeruginosa	MM528	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Signatories

Name Title Name Title

> **Client Manager Team Leader Nutrients**

Team Leader Microbiology Analyst

Chemist

NATA Accreditation No. 992 Accredited for compliance with ISO/IEC 17025 - Testing Samples collected by ALS according to procedure EN/67.

Soil microbiological testing was commenced within 4 days from the day collected unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link

RIGHT SOLUTIONS | RIGHT PARTNER

Page: Page 1 of 2
 Page:
 Page 2 of 2

 Batch No:
 19-41008

 Report Number:
 777821

Client: Country Fire Authority

ALS Program Ref: CFALONG

Program Description: Miscellaneous Analysis for CFA Longerenong



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
6241384	LO_HY01	Hydrant - Primary Supply	WATER	17/09/19 09:05
6241385	LO_HY02	Hydrant - Secondary Supply	WATER	17/09/19 09:10

Analysis - Analyte	Sample No. Site Code Units	6241384 LO_HY01	6241385 LO_HY02
Temp (Field) - Temperature (Field)	°C	12.8	13.1
pH (Field) - pH (Field)	Units	7.3	7.3
EC (Field) - Electrical Conductivity (Field)	uS/cm	89	89
DO (Field) - Dissolved Oxygen (Field)	mg/L	10.3	10.2
Redox (Field) - Redox Potential (Field)	mV	209.1	201.0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	<2	<2
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Enterolert - Enterococci MPN Enterolert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

A blank space indicates no test performed.