

Client:

Contact:



CERTIFICATE OF ANALYSIS

Batch No: 19-44474

Final Report 778544

Laboratory Wangaratta Laboratory Wangaratta Laboratory

Laboratory Wangaratta Laboratory

Address 48 Faithfull Street,

Wangaratta,

VIC 3677.

Page 1 of 2

Address: Phone 03 5722 2688
Fax 03 5722 4727

Contact:

Page

PO No: Date Sampled: 19-Sep-2019

Sampler Name:
Date Samples Received: 19-Sep-2019
Date Issued: 26-Sep-2019

ALS Program Ref: CFAWANG

Program Description: Analysis for Amiad Water Systems

CFA

Client Ref: WQMP - Wangaratta

NATA

Accreditation No. 992 Accredited for compliance with ISO/IEC 17025 - Testing

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service .

Analysis	Method	Laboratory	Analysis	Method	Laboratory
DO (Field)	EN67.2	Wangaratta	EC (Field)	EN67.2	Wangaratta
pH (Field)	EN67.2	Wangaratta	Redox (Field)	# EA075FD	Wangaratta
Temp (Field)	EN67.2	Wangaratta	BOD5	WP030	Wangaratta
Colilert (2000)	MM514	Wangaratta	Enterolert	MM517	Wangaratta
Ps aeruginosa	MM528	Wangaratta	SS at 104+/- 2°C	WA025	Wangaratta

Signatories

ac-MR/

NameTitleNameTitleClient ManagerWangaratta Lab Coordinator

Microbiologist

Samples collected by ALS according to procedure EN/67.

Soil microbiological testing was commenced within 4 days from the day collected unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link

RIGHT SOLUTIONS | RIGHT PARTNER

Page: Page 1 of 2

Page: Page 2 of 2 Batch No: 19-44474 Report Number: 778544 Client: CFA

ALS Program Ref: **CFAWANG**

Program Description: **Analysis for Amiad Water Systems**



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
6266869	WA_TA01	Underground Tank	WATER	19/09/19 09:00
6266870	WA_HY01	Hydrant SW of Interceptor	WATER	19/09/19 08:50

Analysis - Analyte	Sample No. Site Code Units	6266869 WA_TA01	6266870 WA_HY01
Temp (Field) - Temperature (Field)	°C	12.1	11.5
pH (Field) - pH (Field)	Units	8.5	7.6
EC (Field) - Electrical Conductivity (Field)	uS/cm	240	75
DO (Field) - Dissolved Oxygen (Field)	mg/L	8.6	9.5
Redox (Field) - Redox Potential (Field)	mV	549.0	460.0
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	2	<2
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Enterolert - Enterococci MPN Enterolert	orgs/100mL	1	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

A blank space indicates no test performed.