



CERTIFICATE OF ANALYSIS

Batch No: **26-17910**
Final Report **339247**

Page 1 of 2

Client: [REDACTED]
Contact: [REDACTED]
Address: [REDACTED]

Laboratory
Address

Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179
03 8756 8000
03 9763 1862

Phone
Fax
Contact:

[REDACTED]
[REDACTED]

PO No: **7300507655**

Date Sampled: **02-Mar-2026**

Sampler Name: [REDACTED]
ALS Program Ref: **VEOLIA_CFA**

Date Samples Received: **02-Mar-2026**

Date Issued: **10-Mar-2026**

Program Description: **CFA VEMTC**
Client Ref: **CFA West Sale APWS**

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Scoresby	pH	# CLIENT	Scoresby
Temp.	# CLIENT	Scoresby	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Scoresby	Enterolert	MM517	Scoresby
Legionella	MM527	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Name	Title	Name	Title
[REDACTED]	Client Manager	[REDACTED]	Team Leader Nutrients
[REDACTED]	Analyst	[REDACTED]	Analyst

[REDACTED] by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila
Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
The report shall not be reproduced, except in full.

Page 2 of 2
 Batch No: 26-17910
 Report Number: 339247
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



For holding time compliance, method uncertainty, quality control and brief method summary, please refer to accompanying QC report. When a reported LOR is higher than the standard LOR, this may be due to high moisture content, insufficient sample or matrix interference. LOR = Limit of Reporting

Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
12277604	WTP4-APWS	Alternative Potable Water Supply	WATER	02/03/26 10:15

Analysis - Analyte	Sample No.	LOR	12277604
	Site Code		WTP4-APWS
	Units		
Temp. - Water Temperature (CS)	°C	-	20.5
pH - pH (CS)	Units	-	6.74
Field Chlorine - Free Chlorine (CS)	mg/L	-	1.37
Field Chlorine - Total Chlorine (CS)	mg/L	-	1.58
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	2	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0	0
E.coli, Coliforms - E.coli	cfu/100mL	0	0
Enterolert - Enterococci	MPN/100mL	0	0
Legionella - Total Legionellae	cfu/mL	10	<10
Legionella - Legionella pneumophila	cfu/mL	10	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	10	<10

A blank space indicates no test performed.