



CERTIFICATE OF ANALYSIS

Batch No: **26-18547**
Final Report **340389**

Page 1 of 2

Client: [Redacted]
Contact: [Redacted]
Address: [Redacted]

Laboratory Address: **Wangaratta Laboratory**
48 Faithfull Street,
Wangaratta,
VIC 3677.
Phone: 03 5722 2688
Fax: 03 5722 4727

Contact: [Redacted]

PO No: **7300507655**

Date Sampled: **04-Mar-2026**

Sampler Name:

Date Samples Received: **04-Mar-2026**

ALS Program Ref: **VEOLIA_CFA**

Date Issued: **16-Mar-2026**

Program Description:

CFA VEMTC

Client Ref:

CFA Wangaratta APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

| Analysis | Method | Laboratory | Analysis | Method | Laboratory |
|-------------------|----------|------------|------------------|----------|------------|
| Field Chlorine | # CLIENT | Wangaratta | pH | # CLIENT | Scoresby |
| Temp. | # CLIENT | Scoresby | BOD5 | WP030 | Wangaratta |
| E.coli, Coliforms | MM698 | Wangaratta | Enterolert | MM517 | Wangaratta |
| Legionella | MM527 | Wangaratta | SS at 104+/- 2°C | WA025 | Wangaratta |

Signatories

| Name | Title | Name | Title |
|------------|--------------------------------|------------|-----------------------|
| [Redacted] | Analyst | [Redacted] | Analyst |
| | Laboratory Co-ordinator | | Microbiologist |
| | Wangaratta | | |

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.
The report shall not be reproduced, except in full.

Page 2 of 2
 Batch No: 26-18547
 Report Number: 340389
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



For holding time compliance, method uncertainty, quality control and brief method summary, please refer to accompanying QC report. When a reported LOR is higher than the standard LOR, this may be due to high moisture content, insufficient sample or matrix interference. LOR = Limit of Reporting

| | | | | |
|------------------------------|-------------------------------|--------------------------------------|-----------------------------|--|
| Sample No 12287921 | Site Code WTP2 APWS | Site Description WTP2 APWS | Sample Type WATER | Sampled Date/Time 04/03/26 11:30 |
|------------------------------|-------------------------------|--------------------------------------|-----------------------------|--|

| Analysis - Analyte | Sample No. | LOR | 12287921 |
|---|------------|-----|-----------|
| | Site Code | | WTP2 APWS |
| | Units | | |
| Temp. - Water Temperature (CS) | °C | - | 27.5 |
| pH - pH (CS) | Units | - | 7.98 |
| Field Chlorine - Free Chlorine (CS) | mg/L | - | 0.28 |
| Field Chlorine - Total Chlorine (CS) | mg/L | - | 0.43 |
| BOD5 - Biochemical Oxygen Demand, 5 Day | mg/L | 2 | <2 |
| SS at 104+/- 2°C - Suspended Solids | mg/L | 2 | 2 |
| E.coli, Coliforms - Coliforms | cfu/100mL | 0 | 0 |
| E.coli, Coliforms - E.coli | cfu/100mL | 0 | 0 |
| Enterolert - Enterococci | MPN/100mL | 0 | 5 |
| Legionella - Total Legionellae | cfu/mL | 10 | <10 |
| Legionella - Legionella pneumophila | cfu/mL | 10 | <10 |
| Legionella - Legionella Species other than L. pneumophila | cfu/mL | 10 | <10 |

A blank space indicates no test performed.