



CERTIFICATE OF ANALYSIS

Batch No: 26-25152
Final Report 346098

Page 1 of 2

Client: [Redacted]
Contact: [Redacted]
Address: [Redacted]

Laboratory
Address

Scoresby Laboratory
Caribbean Business Park,
22 Dalmore Drive,
Scoresby,
VIC 3179

Phone
Fax
Contact:

03 8756 8000
03 9763 1862

PO No: 7300507655

Date Sampled: 01-Apr-2026

Sampler Name: [Redacted]
ALS Program Ref: VEOLIA_CFA

Date Samples Received: 02-Apr-2026

Date Issued: 10-Apr-2026

Program Description: CFA VEMTC
Client Ref: CFA Penshurst APWS

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
Field Chlorine	# CLIENT	Scoresby	pH	# CLIENT	Scoresby
Temp.	# CLIENT	Scoresby	BOD5	WP030	Scoresby
E.coli, Coliforms	MM698	Scoresby	Enterolert	MM517	Scoresby
Legionella	MM527	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Signatories

Name	Title	Name	Title
[Redacted]	Client Manager	[Redacted]	Analyst
[Redacted]	Analyst	[Redacted]	Analyst
[Redacted]	Analyst		

Samples not collected by ALS and are tested as received.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Samples are tested within holding time unless otherwise stated.

Results contained within this report relate only to the samples tested.

The report shall not be reproduced, except in full.

Page 2 of 2
 Batch No: 26-25152
 Report Number: 346098
 Client: Veolia Environmental Services
 ALS Program Ref: VEOLIA_CFA
 Program Description: CFA VEMTC



For holding time compliance, method uncertainty, quality control and brief method summary, please refer to accompanying QC report. When a reported LOR is higher than the standard LOR, this may be due to high moisture content, insufficient sample or matrix interference. LOR = Limit of Reporting

Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
12406714	WTP1-APWS	Alternative Potable Water Supply	WATER	01/04/26 10:30

Analysis - Analyte	Sample No.	LOR	12406714
	Site Code		WTP1-APWS
	Units		
Temp. - Water Temperature (CS)	°C	-	18.9
pH - pH (CS)	Units	-	7.70
Field Chlorine - Free Chlorine (CS)	mg/L	-	0.93
Field Chlorine - Total Chlorine (CS)	mg/L	-	0.97
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	2	<2
E.coli, Coliforms - Coliforms	cfu/100mL	0	0
E.coli, Coliforms - E.coli	cfu/100mL	0	0
Enterolert - Enterococci	MPN/100mL	0	0
Legionella - Total Legionellae	cfu/mL	10	<10
Legionella - Legionella pneumophila	cfu/mL	10	<10
Legionella - Legionella Species other than L. pneumophila	cfu/mL	10	<10

A blank space indicates no test performed.