

CERTIFICATE OF ANALYSIS

Batch No:	18-41754	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	711295	<i>Laboratory</i>	Bendigo Laboratory
<i>Client:</i>	CFA Training Ground - Huntly Campus	<i>Address</i>	Gate 6 Sharon Street, La Trobe University, Bendigo, VIC 3550
<i>Contact:</i>		<i>Phone</i>	03 5441 0700
<i>Address:</i>	PO Box 383 HUNTLY VIC 3551	<i>Fax</i>	03 5444 5208
		<i>Contact:</i>	Client Manager
 <i>PO No:</i>	 4500376060 v708	<i>Date Sampled:</i>	17-Sep-2018
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	17-Sep-2018
<i>ALS Program Ref:</i>		<i>Date Issued:</i>	25-Sep-2018
<i>Program Description:</i>	CFABGO		
<i>Client Ref:</i>	Analysis for Amiad Water Systems		

WQMP
[The hash \(#\) below indicates methods not covered by NATA accreditation in the performance of this service.](#)

Analysis	Method	Laboratory	Analysis	Method	Laboratory
BOD5	WP030	Bendigo	Colilert (2000)	MM514	Bendigo
Ps aeruginosa	MM528	Scoresby			

Signatories

Name	Title	Name	Title
	Bendigo Laboratory Manager		Analyst
	Process Co-ordinator		

Samples collected by ALS according to procedure EN/67.

Soil results expressed in mg/kg dry weight unless specified otherwise. Soil microbiological testing was commenced within 48 hours from the day received unless otherwise stated. Water microbiological testing was commenced on the day received and within 24 hours of sampling unless otherwise stated.

MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.

MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.

Calculated results are based on raw data.

Legionella species refers to Legionella species other than Legionella pneumophila

Measurement Uncertainties values for your compliance results are available at this link





Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5807481		Tank No 8	WATER	17/09/18 11:37
5807482		Tank No 9	WATER	17/09/18 11:32
5807483		Tank No 10	WATER	17/09/18 11:25

Analysis - Analyte	Sample No. Site Code Units	5807481	5807482	5807483
	BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	3	2
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0	0

Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
5807484		Hydrant	WATER	17/09/18 11:48

Analysis - Analyte	Sample No. Site Code Units	5807484
	BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	1

A blank space indicates no test performed.