

CERTIFICATE OF ANALYSIS

Batch No:	19-44914	<i>Page</i>	Page 1 of 2
<i>Final Report</i>	788970	<i>Laboratory</i>	Scoresby Laboratory
<i>Client:</i>	Country Fire Authority	<i>Address</i>	Caribbean Business Park, 22 Dalmore Drive, Scoresby, VIC 3179
<i>Contact:</i>		<i>Phone</i>	03 8756 8000
<i>Address:</i>		<i>Fax</i>	03 9763 1862
		<i>Contact:</i>	

<i>PO No:</i>	4500376081 v707	<i>Date Sampled:</i>	28-Oct-2019
<i>Sampler Name:</i>		<i>Date Samples Received:</i>	29-Oct-2019
<i>ALS Program Ref:</i>	CFALONG	<i>Date Issued:</i>	06-Nov-2019
<i>Program Description:</i>	Miscellaneous Analysis for CFA Longerenong		
<i>Client Ref:</i>	WQMP - Longerenong		

The hash (#) below indicates methods not covered by NATA accreditation in the performance of this service.

Analysis	Method	Laboratory	Analysis	Method	Laboratory
DO (Field)	EN67.2	Scoresby	EC (Field)	EN67.2	Scoresby
pH (Field)	EN67.2	Scoresby	Temp (Field)	EN67.2	Scoresby
BOD5	WP030	Scoresby	Collert (2000)	MM514	Scoresby
Enterolert	MM517	Scoresby	Ps aeruginosa	MM528	Scoresby
Redox Potential	# WA075	Scoresby	SS at 104+/- 2°C	WA025	Scoresby

Analysis conducted outside holding time due to late arrival or delayed extraction/analysis. Based on APHA, VICEPA, AS & NEPM. Results are approximate and for indicative purposes only.

Late Sample Arrival - Redox Potential[6270206,6270207]

Signatories

Name	Title	Name	Title
	Client Manager		Team Leader Nutrients
	Analyst		Analyst



Samples collected by ALS according to procedure EN/67.
 Soil microbiological testing was commenced within 4 days from the day collected unless otherwise stated.
 MM524: Plate count results <10 per mL and >300 per mL are deemed as approximate.
 MM526: Plate count results <2,500 per mL and >250,000 per mL are deemed as approximate.
 Calculated results are based on raw data.
 Legionella species refers to Legionella species other than Legionella pneumophila
 Measurement Uncertainties values for your compliance results are available at this link



Sample No	Site Code	Site Description	Sample Type	Sampled Date/Time
6270206	LO_HY01	Hydrant - Primary Supply	WATER	28/10/19 13:32
6270207	LO_HY02	Hydrant - Secondary Supply	WATER	28/10/19 13:34

Analysis - Analyte	Sample No.	6270206	6270207
	Site Code	LO_HY01	LO_HY02
	Units		
Temp (Field) - Temperature (Field)	°C	16.9	16.7
pH (Field) - pH (Field)	Units	7.7	7.6
EC (Field) - Electrical Conductivity (Field)	uS/cm	92	91
DO (Field) - Dissolved Oxygen (Field)	mg/L	9.1	9.2
BOD5 - Biochemical Oxygen Demand, 5 Day	mg/L	<2	<2
SS at 104+/- 2°C - Suspended Solids	mg/L	5	3
Redox Potential - Redox Potential against Calomel	mV	160	160
Colilert (2000) - E.coli MPN Colilert	orgs/100mL	0	0
Enterolert - Enterococci MPN Enterolert	orgs/100mL	0	0
Ps aeruginosa - Pseudomonas aeruginosa	orgs/100mL	0	0

A blank space indicates no test performed.